

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

TING No. 7125-0065:154 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Faraday Inc., 805 S. Maumee St., Tecumseh, MI 49286
Contact: Steven A. Blohm (517) 423-2111

DESIGN: Models 2700 or *2701 (20-31VDC); followed by -E, -G, -J, -K or -L non-synchronized strobes. Models 2700 or *2701 (20-31 VDC); followed by -M, -R, -T, -Y or -Z synchronized strobes. *Models 2700 or 2701 (120 VAC); followed by -E, -G, -J, -K or -L non-synchronized strobes. All synchronized strobes must be used with Models 5405 and 5406 Sync Module. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

RATING: Electrical: 20-31 VDC; 120 VAC

Candela: -E, -M (15/75cd); -G, -R (30/75cd); -J, -T (60/75cd);
-K, -Y (75cd); -L, -Z (110cd)

Flash Rate: 60 flashes/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed compatible audible signal devices and fire alarm control units. All units are suitable for wall or ceiling mounted. For indoor use only.

*Rev. 09-30-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager